

Preliminary Assessment Report

Project 3019525, 402 25TH AVE E

Assessment Completed: 5/20/2016

Project Description: New description: Demo existing SFR and construct new SFR. Original description: ECA VARIANCE FOR ADDITION TO SFR

Primary Applicant: [Tom Cross](#)

This report lists the results of a preliminary assessment of your project requirements by various city departments. It's based on the project characteristics described on your site plan and preliminary application form. If your project required a pre-application site visit (PASV), the results of that site visit are also included. The goal of this report is to help you create a complete submittal package and reduce the need for corrections once your application has been submitted.

Next Steps

1. Review the requirements in this report and contact the staff members listed below with questions.
2. If a street improvement plan is required, develop and submit it to the Seattle Department of Transportation (SDOT). **The Seattle Department of Construction and Inspections (SDCI) will not accept your permit application until your street improvement plan is approved as 60% complete by SDOT. See [SDOT Client Assistance Memo 2213](#) for guidance about the 60% complete approval process.**
3. Schedule an appointment for permit application intake with SDCI. **Please bring a copy of this report to your intake appointment.**

Questions About This Report

If you have questions about the information in this report, contact the appropriate city staff member for each section.

SDCI Drainage Requirements

Matthew Bateman, (206) 615-1229, Matthew.Bateman@Seattle.gov

SDCI Land Use Requirements

Nikole Coleman, (206) 684-5043, Nikole.Coleman@seattle.gov

Seattle City Light Requirements

Benjamin Rushwald, (206) 733-9830

Seattle Department of Transportation Requirements

Joel Prather, (206) 615-0772, joel.prather@seattle.gov

Seattle Public Utilities Requirements

Steve Resnick, (206) 233-7234, ResnicS@seattle.gov

Other Resources

- General questions about the permit process: Contact the SDCI Applicant Services Center (ASC) at 206-684-8850.
- User-friendly guides to city permitting processes: [SDCI](#) and [SDOT](#).
- [Detailed zoning information](#).
- Visit our [permit type pages](#) for step-by-step instructions and forms for preparing your application and plans for review.

Requirements

SDCI Drainage Requirements

The following requirements are based on the current stormwater and side sewer codes.

****The new 2016 Stormwater Code becomes effective on January 1, 2016. Projects with an accepted application (successful SDCI permit intake) date after December 31, 2015 will be reviewed under the new code. The drainage requirements indicated below are based on the 2016 Stormwater Code. If your project will be submitted prior to January 1, 2016, please contact the SDCI Drainage Reviewer to determine drainage requirements.****

Existing Public Drainage Infrastructure

Combined sewer main location: **E Harrison St / 25th Ave E**

Combined sewer main size: **8" / 8"**

Drainage

Infiltration Investigation Required: **No**

This project is in an area that does not require Infiltration Investigation

Project Type and Drainage Basin

The storm drainage point of discharge (SMC 22.805.020) is located at: **Combined sewer**

Project Type: **Single-family**

Drainage Basin: **NA**

Drainage Control Compliance

Drainage Review Required: **Yes**

Drainage Control Review is required for this project per SMC 22.807.020. Submit a completed **Standard Construction Stormwater Control and Post Construction Soil Management (CSC/SOIL) Plan** and a completed **Standard Drainage and Wastewater Control (DWC) Plan** including the **Site and Drainage Control Summary** from [On-site Stormwater Management Calculator](#).

Note: For projects with 5,000 square feet or more of new plus replaced hard surface, a comprehensive drainage control plan, construction stormwater control plan, soil amendment plan, and drainage report shall be prepared by a licensed engineer.

Soil Amendment Required: **Yes**

All new, replaced, and disturbed topsoil shall be amended with organic matter per rules promulgated by the Director prior to completion of the project to improve onsite management of drainage water flow and water quality per SMC 22.805.030.A, 22.805.040.A, or 22.805.050.A. Complete the **Post Construction Soil Management Plan** on the [Standard CSC/SOIL Plan](#).

On-site Stormwater Management Required: **Yes**

Single-Family projects with 7,000 square feet or more of land disturbing activity, 1,500 square feet or more of new plus replaced hard surface or, if on a lot or parcel created or reduced in size on or after January 1, 2016, 750 square feet or more of new plus replaced hard surface, must implement **On-site Stormwater**

Management (infiltration, dispersion, bioretention, green roofs, permeable pavement, rainwater harvesting, etc.) to manage runoff from all hard surfaces on-site per SMC 22.805.030.B. and Director's Rule 21-2015.

Submit an [On-site Stormwater Management Calculator](#) and show the On-site Stormwater Management BMP's and surface designation on the [Standard Drainage and Wastewater Control Plan](#).

Wastewater

The wastewater point of discharge (SMC 21.16.070.B) is located at **Public Combined Sewer.**

All homeowners and building owners in King County's service area whose home or building was newly connected to the King County sewer system on or after Feb. 1, 1990 must pay a [King County Capacity Charge](#).

Permanent and Temporary Dewatering

The footing drain (if part of building plan) point of discharge ([DPD DR 4-2011](#)) is located at the following: **Combined system.**

Side Sewer

The existing side sewer for a new or converted building or dwelling unit may be reused pursuant to SMC 21.16.240. If there is an increase of dwelling units or buildings the [Side Sewer Evaluation and Certification Form](#) must be completed by a licensed engineer.

SDCI Land Use Code Requirements

Street Requirements

Based on the scope of the proposed project, the following street improvements are required per Chapter 23.53 of the Seattle Municipal Code. Please review Right-of-Way Improvements Manual for design criteria (<http://www.seattle.gov/transportation/rowmanual/manual/>). Show required street improvements on your "enhanced site plan" at SDCI permit application intake. If an SDOT Street Improvement Plan (SIP) is required, please list SDOT project number and SDOT contact name on the enhanced site plan. Street Improvement Plans must be accepted by SDOT prior to SDCI permit application intake.

E HARRISON ST

Based on the documents provided, no street improvements are required per SMC 23.53.015 and SMC 23.53.006

25TH AVE E

Based on the documents provided, no street improvements are required per SMC 23.53.015 and SMC 23.53.006

Land Use

Based on the preliminary scope, the project may qualify for a specific exemption under the Environmentally Critical Areas Ordinance. Application and decision on the exemption must be made before submittal of a application. See CAM 327 for more details.

Seattle City Light Requirements

Notes to Applicant

For new service, please contact the Electrical Service Representative for your area several months before new service is required to determine your electric service design, service location and what kind of service is available at the building site. An Application for Electrical Service must be submitted to Seattle City Light. The Electrical Service Representative should also be contacted to coordinate electrical disconnections prior to demolition and temporary power for construction. Your Electrical Service Representative is: Erin Hunter, 206-684-4297, erin.hunter@seattle.gov. Be advised that it is the applicant's responsibility to seek guidance from City Light. Failure to contact City Light early in the permit process could severely impact your project's scope, schedule and budget. This responsibility rests solely with the applicant.

SDOT Requirements

The City of Seattle's Right-of-Way Improvements Manual (ROWIM) and SDOT's Street & Sidewalk Pavement Opening and Restoration (PORR) Director's Rule 2004-02 may be accessed from SDOT's Street Use website at: http://www.seattle.gov/transportation/stuse_docs.htm. Whenever possible, specific reference notation for

these two design documents is noted next to the design characteristics below. Be advised that these specific section and chapter references are provided as preliminary guidance only and are not comprehensive in scope.

SDOT Permitting Information

Initial Review Deposit: To be determined

SDOT Plan Requirements: Plan

SDOT Permit Requirements: Group 1:Over-the-Counter. Obtain from SDOT anytime prior to construction in the right of way.

All private encroachments in the public right-of-way (ROW) require a 30-day permit that is renewed annually.

Street Improvement Requirements

25TH AVE E

Tree protection: Removal of trees in the public right-of-way (ROW) is prohibited. Projects must be designed to accommodate existing trees in the ROW. Exceptions to this policy require review and approval by SDOT Urban Forestry. For residential projects, call (206) 684-TREE; for all other projects, call (206) 684-5693. Contact SDOT Urban Forestry immediately if you are proposing to remove street trees. If an exception from street tree removal is not granted, the project will need to be redesigned to preserve street trees. Coordinate with SDOT UF for existing st tree conflict with proposed drwy.

All improvements on private property must accommodate the right of way elevation at the property line using the standard cross-section in the ROWIM. Right of way grading may be required to provide vehicular and pedestrian access that meets the standard cross-section.

New/replacement sidewalk: See Seattle Right of Way Improvements Manual (ROWIM) as well as the City of Seattle Standard Plan 420, 421 and 422. Repair & restoration of existing as needed.

New/Replacement Curb: See Seattle Right of Way Improvements Manual (ROWIM) and the City of Seattle Standard Plan 410. Construct new curb & restoration @ existing drwy closure.

New/replacement driveway: If there is a concrete curb in front of the project, the Street Use curb cut permit is issued by DPD. If there is not a concrete curb in front of the project, a Group 2 Street Use permit must be issued by Street Use. Refer to Standard Plan 430 for driveway curb cut standards. Construct new drwy per SDCI permit & COS std plan 430A.

Other requirements: Proposed drwy conflicts with existing st trees and fire hydrant - relocation is big \$\$\$.

Discretionary ROW Improvements

Utilities such as poles, utility vaults, and fire hydrants may need to be relocated to accommodate your required street improvements. See Right of Way Improvement Manual (ROWIM) section 4.20 for clearance requirements.

SPU Requirements

Flow Control Compliance

Soil Amendment. Retain and protect undisturbed soil in areas not being developed, and prior to completion of the project, amend all new, replaced, and disturbed topsoil (including construction lay-down areas) with organic matter to the extent required by and in compliance with the rules promulgated by the Director.

Other Requirements

Owners of residential property occupied by a tenant who will be displaced by housing demolition, substantial rehabilitation, change of use, or removal of use restrictions may need to obtain a Tenant Relocation License. Refer to SDCI Tip 123, Seattle's Tenant Relocation Assistance Ordinance, for further information and instructions or call (206) 684-7979.

If your project involves additions or modification to or demolition of an existing building that contains four or more dwelling units or 4,000 square feet or more of non-residential area, and the building is a designated historic landmark or is 50 years old and meets the criteria set forth in SMC 25.12 for landmark designation, SEPA is required. Please contact the Department of Neighborhoods at (206) 684-0228 or www.seattle.gov/neighborhoods/preservation to determine if your building is a designated landmark or if a referral is necessary to determine if the building meets the criteria in SMC 25.12. Refer to Tip 208 for information regarding the application requirements for a SEPA review and Tip 3000 for information regarding landmarks and historic preservation.

If the scope of your proposed project changes before your SDCI intake appointment or SDOT street improvement plan application, the requirements in this report may change. If there are municipal code and ordinance changes before our SDCI intake appointment, the project must meet the new code requirements. Additional street improvement requirements may be triggered if a permit application for a development project on adjacent property is also undergoing review.

Please be aware that all persons or companies working within the City limits, including all contractors, subcontractors, permit expeditors and other service providers are required to possess a valid City of Seattle business license. This license is required in addition to any other licenses required by the State of Washington, such as a contractors' license or state business license. For more information about City of Seattle business licenses, please contact inspector Michale Crooks at 206-684-8871, Michale.Crooks@seattle.gov, or visit the [Licensing and Tax Administration Division website](#).